

Design of a Biomass Cogeneration Plant

UNIVERSITY OF NEW BRUNSWICK

Engineering
Design

By: Devyani Ambwani, Mikayla Dumas, Jonathan Levasseur, Patrick Watling

Project Background and Objectives

The UNB central heating plant (CHP) is tasked with generating the steam required for campus and external clients. CHP has five boilers which utilize a variety of fuels. Boiler #1, the biomass boiler, is nearing the end of its service life and must be replaced. The objectives for this project are listed below:



Explore proven and emerging technologies as they relate to the replacement of boiler #1.

Investigate cogeneration

economic and technical

viability of the design.

and determine the



Recommend a process to replace the current biomass boiler and its auxiliaries.




Position CHP to be a reliable, efficient and sustainable source of energy and steam for UNB.

Cogeneration

- The cost to produce a kWh of electricity was determined to be \$0.08/kWh.
- When compared to the \$0.11/kWh cost that NB Power charges, it was determined that cogeneration was worth further investigation.
- The proposed boiler will have a 4:1 turndown ratio and a minimum steam production capacity of 3,600 kg/hr to accommodate summer load.
- Based on the average monthly CHP steam output shown in Figure 1, the use of two turbines is the most efficient way to maximize electricity production.


Figure 1 - Turbine Utilization Chart



- Small Turbine Only 3,600 kg/hr ■ Both Turbines - 15,000 kg/hr
- Large turbine Only 11,400 kg/hr

 □ Total Steam Output

Proposed System



- → Varying Superheated Steam Outputs
 - 3,600 kg/hr Only small turbine online, 145 kW output
 - 11,400 kg/hr Only large turbine online, 530 kW output
 - 15,000 kg/hr Both turbines online, peak output of 675 kW
- During an intermediate boiler output, saturated steam bypasses superheater and goes through a pressure relief valve (PRV) before being sent to users.
- → 99.9% of the particulate in the flue gas is removed using a cyclone and an electrostatic precipitator (ESP).
- → The ash is collected and sold for agricultural use.

Economic Analysis



28% \$0.5 M 1%

Annual Revenue

\$8.5 M

Total Plant

Electricity Portion

New vibrating grate biomass boiler was successfully designed with 76% thermal efficiency.

% of Installed Cost

72%



The electricity portion of the design is **not economically feasible** on its own.



Return on Investment

33%

Boiler #1 should be replaced with another steam only process



Internal Rate of Return

32%

3%

The use of biomass fuel is in line with new campus climate change action plan.

Payback Period

3 Years

38 Years

Acknowledgements:

Conclusions and Recommendations

We would like to express our sincere gratitude to Mr. Douglas Marion and his team at the UNB Central Heating Plant, Dr. Michel Couturier and Mr. Mike Richard for their mentorship, Dr. Guida Bendrich for her feedback and course management, and Ms. Demerson-Locke and Ms. Annett for supporting the team in delivering project requirements.